



NOTE:

- 1. For outdoor unit installation, allow at least 2 sides of space around the unit ensure ventilation flue.
- $2. \\ \mbox{The connecting pipe}$, should all the insulated with insulation pipe.
- 3. Piping length is within 20m.
- 4. Height different of the piping between the indoor unit and outdoor unit should be within 10m.