




LCIE

BV LCIE 1966AS10HRR33058
CHINA
Number 1966AF10HRR33058

ATTESTATION of conformity with European Directives



Product: Split type AIR CONDITIONER
Reference RPFC-3.0UFE1NH (Indoor unit) with RAS-3.0UFESNH1 (Outdoor unit)
RCI-3.0UFE1NH (Indoor unit) with RAS-3.0UFESNH1 (Outdoor unit)
RPIL-3.0UFE1NH (Indoor unit) with RAS-3.0UFESNH1 (Outdoor unit)
Issued to Hitachi-Johnson Controls Air Conditioning, Inc.
Address 1-16-1, Kaigan Minato-ku, Tokyo, Japan
Manufacturer Hitachi-Johnson Controls Air Conditioning, Inc.
Technical characteristics 220-240V~, 50Hz, 4100W, 18,1A, Class I, IPX4 for outdoor unit, Max. Discharge pressure: 4,3MPa, Max. Suction pressure: 1,6MPa, R32, 1,40kg

The submitted sample of the above equipment has been tested for  marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

| <i>Standards</i> | <i>Report number</i> | <i>Report date</i> |
|--|----------------------|--------------------|
| EN 60335-1:2012 +A11:2014 +A13:2017 EN 60335-2-40:2003 +A11:2004 +A12: 2005 +A1:2006 +A2:2009 +A13:2012 EN 62233:2008 | HRR-19OC1578DTQDP | 30/10/2019 |

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The  marking may be affixed if all relevant and effective European Directives with  are applicable

Shanghai (P.R. China), Oct. 30th, 2019

Yi ZONG
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有
限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com

Version 3/2016.02.19