



BV LCIE 1966AS10HRR33063
 CHINA
 Number 1966AF10HRR33063

ATTESTATION of conformity with European Directives

Product: Split type air conditioner
Reference: RCI-5.0UFE1NH (Indoor unit) with RAS-5.0UFESMH1 (Outdoor unit)
 RPIH-5.0UFE1NH (Indoor unit) with RAS-5.0UFESMH1 (Outdoor unit)
 RPFC-5.0UFE1NH (Indoor unit) with RAS-5.0UFESMH1 (Outdoor unit)
Issued to: Hitachi-Johnson Controls Air Conditioning, Inc.
Address: 1-16-1, Kaigan Minato-ku, Tokyo, Japan
Manufacturer: Hitachi-Johnson Controls Air Conditioning, Inc.
Technical characteristics: 380-415V, 3N~, 50Hz, 6400W, 11,6A, Class I, IPX4 for outdoor unit,
 Max. Discharge pressure: 4,3MPa, Max. Suction pressure: 1,6MPa,
 R32/2,5Kg,

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:
 - Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60335-1:2012 +A11:2014 +A13:2017 EN 60335-2-40:2003 +A11:2004 +A12:2005 +A1:2006 +A2:2009 +A13:2012 EN 62233:2008	HRR-19OC1586DTQDP	30/10/2019

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
 The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), Oct. 30th, 2019

Yi ZONG
 Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
 Information given in this document, are related to the tested specimen of the described electrical sample.